

**Request for Expressions of Interest  
Order for Professional Services No. A3651  
Underground and Above Ground Storage Tank Compliance, Maintenance and Testing**

**Responses to Inquiries**

**1. Inquiry:** The EOI for OPS A3651 lists thirty-five facilities located on the Garden State Parkway and New Jersey Turnpike roadways that are considered within the Scope of Work for this Contract. Would you please provide additional information regarding the Parkway Chevalier Avenue Sub-Yard (MP 125.0 NB) and the Turnpike Extension Yard (Route 130 – Exit 6). Specifically, are there fuel storage tanks located at these two facilities that may be subject to NJDEP existing or proposed new rules regarding the requirements applicable to Underground Storage Tanks (USTs) or Federal aboveground storage tank (AST) Spill Prevention, Control and Countermeasure (SPCC) Plans?

**Response:** A 3,000-gallon AST diesel fuel is located at the Chevalier Sub-Yard while a 5,000-gallon diesel fuel AST is located at the Turnpike Extension Yard, thus neither are subject to NJDEP existing or proposed new rules regarding requirements applicable to USTs. An SPCC plan exists for the Chevalier Ave Sub-Yard while an SPCC plan is being developed for the Turnpike Extension Yard. In either case, if an SPCC plan were required, said SPCC would be completed under the on-call portion of OPS A3651.