

**New Jersey Turnpike Authority
Engineering Department**

**Order for Professional Services No. T3677
Engineering Services for the
Demolition Contract Documents for Former Turnpike Administration Building
MP 83.2 SB
Township of East Brunswick
Middlesex County**

**Responses to Inquiries
Request for Expressions of Interest**

December 13, 2017

1. **Inquiry:** On Page 6 under the paragraph referring to the maximum number of pages for the EOI, it's excluding several items, however it does not seem to list resumes as part of the excluded list. Please confirm this is correct.
Response: Resume pages are included in the page count total listed on Page 6.
2. **Inquiry:** The Helipad, Radio Tower and the Generator associated with the Radio Tower are to remain?
Response: Yes, these items will remain.
3. **Inquiry:** If the Helipad is to remain, does access to it have to be maintained during demolition?
Response: Yes, it must be maintained during demolition.
4. **Inquiry:** Should it be assumed that all existing pavement is being removed as part of the demo?
Response: No, it is not to be removed.
5. **Inquiry:** Please confirm if NJTA operates any equipment to support the Radio Tower that is in the existing HQ Building (including Radio Room). If so, please confirm if this equipment would need to be moved to a new ITS enclosure.
Response: Power and communication lines run through the existing East Brunswick Administration Building to the Radio Tower. These lines will need to be re-routed prior to demolition. There is no other ITS equipment that needs to be maintained.
6. **Inquiry:** Please confirm if as-builts are available for the existing Radio Room and fiber/electric service connections to the Radio Tower.
Response: The Radio Room and Tower are depicted on the Ground Floor Plans of Contract No. R-303. Please contact Tony Valte at (732) 750-5300, extension 8244 regarding availability of other as-built documents.