


- NOTES**
- Lighting standards shown shall be used to replace existing installations on the New Jersey Turnpike only. For new installations, see details on Standard Drawings E-1 to E-9.
 - Concrete bases shall be used only where right of way limitations or other field conditions prevent use of junction box foundations.
 - Sketches shown on this sheet are provided to show overall dimensions of each lighting standard type. For specific details, including mounting dimensions of components, materials, etc. see Standard Drawings ER-02 through ER-06.
 - The following chart shall be used as a cross-reference when designing new lighting systems.

IF YOU WOULD USE A:	USE A:	IF YOU WOULD USE A:	USE A:
TYPE 1	L-15-26	TYPE 7	L-15-40
TYPE 2	L-8-26	TYPE 8	L-8-40
TYPE 3	L-15-26-SB	TYPE 9	L-15-40-SB
TYPE 4	L-8-26-SB	TYPE 10	L-8-40-SB
TYPE 5	L-15-26-T	TYPE 11	NOT APPROVED
TYPE 6	L-8-26-T	TYPE 12	L-8-40-T

If you use this Standard Drawing:	
You also need	-
You may need	ER-03, ER-04, ER-05

	BY	DATE
MADE	EMG	05/2009
TRACED	MDC	05/2009
CHECKED	EMG	05/2009
SUPERVISED	ALB	05/2009

TYPICAL LIGHTING STANDARD TYPES
Scale: 3/16" = 1'-0"



APP.	NO.	DATE	REVISION
	0	05/2009	ORIGINAL DRAWING

ELECTRICAL RETROFIT
NEW JERSEY TURNPIKE AUTHORITY
NEW JERSEY TURNPIKE
LIGHTING STANDARD KEY SHEET

HNTB 145 RT. 46 WEST, SUITE 400, WAYNE, NJ 07470 - CO# 24G28000700	STANDARD DRAWING ER-01
---	---

ANTHONY L. BARTELLO
N.J.P.E. License No. GE 45842